



DESIGN STANDARDS FOR: TOILET PARTITIONS

1. No partitions at urinals.
2. At toilets, use fiberglass reinforced plastic units, pewter/gray color
 - a. Acceptable Manufacturer: General Partitions Mfg. Corp., which is located at: 1702 Peninsula Dr. P. O. Box 8370; Erie, PA 16505; Tel: 814-833-1154; Fax: 814-838-3473; info@generalpartitions.com, <https://www.generalpartitions.com>
 - b. Panels & doors:
 - i. Fiberglass reinforced plastic panels, doors and pilasters. Textured fiberglass reinforced plastic, 0.060 inch (1.5 mm) thick, laminated to a core material.
 - c. Core Material:
 - i. Per ANSI 208.1: Medium Density Series, wood particle board with 45 pounds minimum density.
 - d. Edges:
 - i. Textured fiberglass reinforced plastic, bonded to faces and core.
 - e. Fittings:
 - i. Pilaster Trim: Minimum 3 inches high 0.031 inch thick (76 mm by 0.76 mm thick) stainless steel shoe.
 - f. Hardware:
 - i. Combination Latch Keeper and Door Stop with Rubber Bumper: Extruded aluminum. Cast alloy, chrome plated or Cast Stainless

END OF SECTION