

# **DESIGN STANDARDS FOR:** INTERIOR LIGHTING

#### Lighting standard:

- 1. Herculux model #H1212L series 3800 ceiling mount compact fluorescent 13 watt twin manufactured by Kenall.
- 2. Note: An approved equal will not be accepted. Sole source justification is based on bulk parts on hand; ease on maintenance time, availability, and vandal resistance.

# Herculux TM

H1212L Series (3800)

Ceiling Mount/Surface – Compact Fluorescent – Incandescent

Lens/Housing: One-piece wraparound lens/housing (U.V. stabilized, high impact, virgin injection molded polycarbonate). Clear Prismatic refractor: Nominal thickness .125". 150 Watt Maximum (Incandescent)



Width	Width	Depth	
12"	12"	4.5"	

#### Institutional High Abuse Lighting

#### Specifications

Baseplate: 16-gauge CRS. Baseplate provided with four-point mounting holes, one wireway hole - see Cross Section/Details. White urethane powder coat finished - 5-step pre-treatment; laboratory salt spray test: 1,000 hours. See Options or Accessories for marine grade aluminum baseplate (AL) and CRS surface conduit adapter (SA).


**Electrical:** Magnetic ballasts normal power factor standard. See Options for power factor corrected ballasts. Electronic ballasts high power factor.

Gasket: Die-cut closed cell neoprene gasket seals lens/housing to mounting surface.

 $\textbf{\textit{Hardware:}} \ \ \text{Four stainless steel POSIGRIP} \ \ \text{fasteners secure lens/housing to baseplate.}$ 

Listings/Certifications: UL and CUL listed for Wet Locations.

Installation: Standard four-point mounting required for Peace of Mind Lifetime Guarantee







1020 Lakeside Drive Gurnee, Illinois 60031 847-360-8200 FAX 847-360-1781 www.kenall.com

# Herculux<sup>™</sup> Cross Section/Details


#### H1212D Series (5700)

# Cross Section/Details







**Back Mounting View** 



Horizontal Arm Bracket (HRZ)

#### Photometric Information Candlepower Distribution






Horizontal Plane Isofootcandle Line					
	7	8	9	10	
a	6.53	5.00	3.95	3.20	
Ь	2.61	2.00	1.58	1.28	
C	1.31	1.00	0.79	0.64	
d	0.65	0.50	0.40	0.32	
e	0.26	0.20	0.16	0.13	
f	0.13	0.10	0.08	0.06	

Report Number: ITL 39162P Lamp: 100 Watt MH, 8500 Lumens Lens: Clear Prismatic Polycarbonate Grid lines in units of mounting height

Wall Mount Mounting Height (in fact)

# Ceiling 2583 \_ [80° 1937 \_ 1292 \_ 646 \_ \_ \_ \_ 90°



Horizontal Plane Isofootcandle Line						
	7	8	9	10		
a	9.14	7.00	5.53	4.48		
b	6.53	5.00	3.95	3.20		
C	2.61	2.00	1.58	1.28		
d	1.31	1.00	0.79	0.64		
e	0.65	0.50	0.40	0.32		
f	0.26	0.20	0.16	0.13		

Report Number: ITL 39162 Lamp: 150 Watt HPS, 16000 Lumens Lens: Clear Prismatic Polycarbonate Grid lines in units of mounting height

#### Peace of Mind Guarantee

Kenall high abuse luminaires are designed and built to take exceptional physical punishment. When installed according to our instructions, Kenall will repair or replace any fixture rendered inoperable due to physical abuse for the product life of the original installation.



Lifetime Guarantee™

#### **Quick Specification**

Housing: Die-cast aluminum housing.

**Lens:** One-piece lens (U.V. stabilized, high impact, virgin injection molded polycarbonate)

**Reflector:** High efficiency textured aluminum reflector.

**Hardware:** Four stainless steel POSIGRIP™ fasteners secure lens to housing.

Socket: Shock absorbing lamp socket.

Listings: UL and CUL listed for wet locations.

## Project Information

Job Name

Job Location

Fixture Type

Quantity

Approved by

Catalog Number

Date

KENALL

1020 Lakeside Drive Gurnee, Illinois 60031 847-360-8200 FAX 847-360-1781 www.kenall.com

© 2002 Kenall

Design Standard No. 16511.00 Date: <u>August 23, 2007</u> Page 4 of 4

### **END OF SECTION**