



NOTES:

1. JOINTS SHALL BE PLACED AT 10' INTERVALS.
2. JOINTS SHALL BE CUT VERTICALLY AND TO A DEPTH OF 5 INCHES.

<p>APPROVED</p> <p>_____</p> <p>City Engineer Date</p>	<p>CITY OF BELLINGHAM</p> <p>EXTRUDED CEMENT CONCRETE CURB</p>	<p>DRAWING</p> <p>CG-212</p>
---	---	-------------------------------------