



**JOINTS:**

JOINTS SHALL BE PLACED AT 10' INTERVALS.  
 JOINTS SHALL BE CUT VERTICALLY AND TO A  
 DEPTH OF 5 INCHES.

APPROVED  
*Raymond R. Smith*  
 City Engineer

*11/29/04*  
 Date

CITY OF BELLINGHAM  
 EXTRUDED CEMENT  
 CONCRETE CURB

DRAWING  
 CG-212