



NOTES:

- CONTROL JOINTS @ 5'-0" UNLESS NOTED OTHERWISE.
- NATIVE SUB-BASE CONFORMANCE WITH STORM WATER SITE PLAN TO BE CONFIRMED IN WRITING BY THE DESIGN ENGINEER AND SUBMITTED TO CITY PROJECT ENGINEER PRIOR TO INSTALLATION OF DRAIN ROCK.
- DESIGN ENGINEER TO CERTIFY DRAIN ROCK BASE FOR COMPACTION AND DRAINAGE PRIOR TO POROUS CONCRETE INSTALLATION.
- THIS CROSS SECTION NOT TO BE USED FOR RAMPS OR DRIVEWAY CROSSINGS.
- SIDEWALK AND CURB DRAINAGE TO BE INSTALLED AS SPECIFIED IN THE APPROVED PROJECT STORM WATER SITE PLAN.

APPROVED

City Engineer

12 SEPT 2016

Date

CITY OF BELLINGHAM

POROUS CONCRETE
SIDEWALK

DRAWING

CG-235