

Common Water Quality Results, Bellingham (2024)

Parameter	Units	Leaving the Water Filtration Plant (Fe, O ₂ 2023)	Midpoint in Water Distribution System*
pH	SU	7.99	8.18
Alkalinity	mg/L- CaCO ₃	26.3	27.4
Free Chlorine Residual	mg/L	0.86	0.46
Dissolved Oxygen	mg/L	10.5	10.4
Turbidity	NTU	0.04	0.160
Iron	mg/L	<0.01	<0.01

mg/L also known as parts per million

*Strider Loop in Dakin-Yew Zone