



#### NOTES

1. WHEN BOLT DOWN GRATES ARE SPECIFIED IN THE CONTRACT, PROVIDE TWO SLOTS IN THE GRATE THAT ARE VERTICALLY ALIGNED WITH THE HOLES IN THE FRAME. LOCATION OF BOLT DOWN SLOTS VARIES AMONG DIFFERENT MANUFACTURERS.
2. REFER TO STANDARD SPECIFICATION 9-05.15(2) FOR ADDITIONAL REQUIREMENTS.
3. FOR FRAME DETAILS, SEE STANDARD PLAN B-2A.
4. THE THICKNESS OF THE GRATE SHALL NOT EXCEED 1 5/8"

APPROVED

*Rory J. Smith*  
City Engineer

5/29/14  
Date

CITY OF BELLINGHAM  
HERRINGBONE GRATE FOR  
CATCH BASINS AND INLETS

DRAWING

DR-502