



NOTES:

1. MAXIMUM 3"Ø PLASTIC PIPE (SCH 40) PLACED WITH BOTTOM OF PIPE APPROXIMATELY ½" ABOVE GUTTER LINE AND NOT TO EXTEND BEYOND FACE OF CURB.
2. DRAIN TO BE MADE OF RIGID PLASTIC PIPE ONLY. NO FLEXIBLE FOOTING DRAIN PIPE ALLOWED.
3. IF THE CURB AND GUTTER IS EXISTING AT THE TIME OF PIPE INSTALLATION, THE CURB, GUTTER, AND/OR SIDEWALK MUST BE SAWED ALONG THE EXISTING CONSTRUCTION JOINTS, REMOVED AND THEN REPLACED AS INDICATED.
4. BEDDING UNDER THE CONCRETE SIDEWALK, THE CURB, AND THE GUTTER TO BE OF THE SAME MATERIAL THAT EXISTED AT THE TIME OF REMOVAL.
5. USAGE FOR THIS DRAIN SYSTEM IS LIMITED TO CONNECTION OF ROOF DRAINS OR PARKING AREA DRAINAGE. NO FOOTING OR SUBSURFACE DRAINS SHALL BE CONNECTED TO THE OUTLET.

APPROVED

Thomson
City Engineer

11/29/04

Date

CITY OF BELLINGHAM

RESIDENTIAL SIDEWALK DRAIN

DRAWING

DR-525