



NOTES:

1. UNLESS OTHERWISE INDICATED ON PLAN, SIDE SERVICE SHALL BE LOWER THAN THE LOWEST LOT ELEVATION.
2. WHEN REPLACING EXISTING SIDE SERVICE, CONTRACTOR SHALL VERIFY POSITIVE FALL, OTHER EXISTING CONNECTIONS, AND SAGS OR DEFLECTIONS IN PIPE, AS PER ASTM F 1743 8.6.

NOT TO SCALE

APPROVED <i>John D. Smith</i> City Engineer	4-28-05 Date	CITY OF BELLINGHAM STORM DRAIN SIDE SERVICE	DRAWING DR-530
---	-----------------	--	-------------------