



**NOTES:**

1. MAXIMUM SPACING BETWEEN PIPE ANCHORS SHALL BE 36'.
2. PIPE ANCHORS SHALL BE PLACED SO THAT 1' OF THE ANCHOR WILL BE BELOW THE TRENCH LIMITS ON UN-DISTURBED GROUND.

APPROVED

*Royal Routh*  
City Engineer

*11/29/04*

Date

CITY OF BELLINGHAM

PIPE ANCHOR

DRAWING

SS-760