



**NOTES:**

1. MAINTAIN CONSTANT RISE IN PIPING.
2. STANDPIPE PROTECTION MAY BE REQUIRED DEPENDING ON LOCATION PER WA-804

<p>APPROVED</p> <p>City Engineer</p>	<p>CITY OF BELLINGHAM</p> <p><b>TYPICAL VACUUM/AIR RELEASE VALVE-BELOW GROUND</b></p>	<p>DRAWING</p> <p><b>WA-818</b></p>
<p>19 AUG 2019</p> <p>Date</p>		