



NOTES:

1. PIPE ZONE BEDDING SHALL BE GRAVEL BACKFILL FOR PIPE ZONE BEDDING PER WSDOT 9-03.12(3).
2. ALL TRENCHES IN THE RIGHT-OF-WAY, UNDER PAVEMENT, OR OTHER AREAS WHERE SETTLEMENT WILL BE DETRIMENTAL SHALL BE BACKFILLED WITH IMPORTED TRENCH BACKFILL PER WSDOT SECTION 9-03.19, BANK RUN GRAVEL FOR TRENCH BACKFILL, AND COMPACTED TO 95% DENSITY AS SPECIFIED IN SECTION 3-03.3(14)D. TRENCHES IN UNIMPROVED ROW MAY BE BACKFILLED WITH NATIVE MATERIAL WHEN APPROVED BY THE CITY ENGINEER.
3. WATER MAIN SHALL HAVE A MINIMUM COVER OF 3.5 FEET.

APPROVED _____ City Engineer Date	CITY OF BELLINGHAM WATER PIPE TRENCH DETAIL	DRAWING WA-820
--	--	------------------------------