



PLAN VIEW

SECTION VIEW

NOTE

- ALL DIMENSIONS APPLY TO STABLE TRENCH WALLS. UNDER VARIABLE CONDITIONS, SIZE OF THRUST BLOCK SHALL BE DETERMINED BY THE CITY ENGINEER.
- WRAP ALL FITTINGS WITH VISQUINE MIN. 6" PAST FLANGES, PRIOR TO POURING CONCRETE THRUST BLOCK.

100 P.S.I. OPERATING PRESSURE

SIZE	WIDTH	DEPTH
6"	1'-6"	1'-6"
8"	2'-0"	2'-0"
10"	2'-6"	2'-6"
12"	3'-0"	3'-0"
16"	4'-6"	3'-6"
20"	6'-0"	4'-0"
24"	7'-0"	5'-0"

APPROVED

[Signature]
City Engineer

1/11/05
Date

CITY OF BELLINGHAM
THRUST BLOCK-TEE

DRAWING
WA-862