



BEFORE CITY CONNECTION  
TO CONTRACTORS PIPE

TEMPORARY BLOWOFF FOR  
PRESSURE TEST AND BACTERIA  
SAMPLE BEFORE CITY CONNECTION

PROPERTY LINE

FIRELINE

STAR BOLT

REVERSE THRUST  
BLOCK

THRUST BLOCK

3/4"  $\phi$  PLATED  
THREADED ROD

TAPPING SADDLE  
AND VALVE (OR TEE)

WATERMAIN

FIRELINE

REVERSE THRUST BLOCK  
ATTACHED TO FITTING  
WITH THREADED ROD

STAR BOLT (TYP)

THRUST BLOCK

REVERSE THRUST BLOCK  
ATTACHED TO FITTING  
WITH THREADED ROD

APPROVED

*Kerry J. Smith*

City Engineer

9/17/07

Date

CITY OF BELLINGHAM  
APPROVED RESTRAINTS

DRAWING

WA-884