



NOTES:

1. EXISTING VALVES AND/OR EXISTING MAIN= BEGINNING STATIONING= 0+00 — BEGIN NEW STATIONING AT ALL HYDRANT TEES, NEW MAIN TEES AND BLOW-OFFS.
2. NOTE TAP STATIONING AND END STATIONING IS FROM THE NEAREST TEE OR VALVE BACK.
3. MEASURE DISTANCE FROM MAIN TO SHUT OFF AND SHUT OFF (PROPERTY STOP) TO END OF 3/4\".
4. MEASURE DISTANCE FROM TAP TO A POINT OPPOSITE (AT 90°) THE PROPERTY STOP AND STATION THIS POINT. (EXAMPLE 2+10).
5. MEASURE DISTANCE FROM THIS POINT (ITEM #4) TO THE PROPERTY STOP (DISTANCE OUT AT 90°)
6. MEASURE DEPTH OF ALL SERVICES AND MAINS.

APPROVED

 City Engineer

12/28/04
 Date

CITY OF BELLINGHAM
 TYPICAL WATER MAIN DRAWING
 OF RECORD
 (INCLUDING SERVICES)

DRAWING
 WA-897