



- * PIPE COVER LESS THAN 2 FEET IS PERMITTED WITH APPROVAL FROM THE CITY AND BACKFILL SHALL BE CONTROLLED DENSITY FILL FROM THE PIPE SPRINGLINE UP, PIPE COVER SHALL NOT BE LESS THAN 1-FOOT.
- ** UNSUITABLE FOUNDATION MATERIAL SHALL BE REMOVED AND REPLACED WITH GRAVEL BACKFILL FOR FOUNDATIONS, CLASS B, PER WSDOT SECTIONS 7-08.3(1)A AND 9-03.12(1)B.

NOTES:

1. BEDDING MATERIAL FOR PIPE SHALL BE PEA GRAVEL CONFORMING TO WSDOT 9-03.1(4)C WITH AASHTO NO. 8.
2. ALL TRENCHES IN THE RIGHT-OF-WAY, UNDER PAVEMENT, OR OTHER AREAS WHERE SETTLEMENT WILL BE DETRIMENTAL SHALL BE BACKFILLED WITH IMPORTED TRENCH BACKFILL PER WSDOT SECTION 9-03.19, BANK RUN GRAVEL FOR TRENCH BACKFILL, AND COMPACTED TO 95% DENSITY AS SPECIFIED IN SECTION 3-03.3(14)D. TRENCHES IN UNIMPROVED ROW MAY BE BACKFILLED WITH NATIVE MATERIAL WHEN APPROVED BY THE CITY ENGINEER.

APPROVED _____ City Engineer Date	CITY OF BELLINGHAM STORM PIPE TRENCH SECTION DETAIL	DRAWING DR-538
--	--	--------------------------